

# KOMO<sup>®</sup> product certificate



Number	K4348/04	Replaces	K4348/03
Issued	2012-07-01	Dated	2009-02-01
Valid until	Indefinite	Page	1 of 3

Three-layer PVC pipes for underground sewerage 110 - 630 mm

## DYKA B.V.

### STATEMENT BY KIWA

This product certificate is issued on the basis of BRL 2023 "Structured-wall pipes and fittings of PVC-U for non-pressure underground and indoor sewerage " issued on 15 March 1997 by Kiwa, including alteration sheet date 2004-01-01, in accordance with the Kiwa Regulations for Product Certification.

Kiwa declares that legitimate confidence exists that the by the producer manufactured Three-layer PVC pipes for underground sewerage 110 - 630 mm comply with the technical specifications as laid down in this product certificate, provided that Three-layer PVC pipes for underground sewerage 110 - 630 mm have been marked with the KOMO<sup>®</sup>-mark in the manner as indicated in this product certificate.

Bouke Meekma  
Kiwa

The certificate is listed in the overview on the website of Stichting KOMO: [www.komo.nl](http://www.komo.nl).  
Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.

**Kiwa Nederland B.V.**  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands

Tel. +31 70 414 44 00  
Fax +31 70 414 44 20  
[info@kiwa.nl](mailto:info@kiwa.nl)  
[www.kiwa.nl](http://www.kiwa.nl)

**Holder of Certificate**  
Dyka B.V.  
Produktieweg 7  
Postbus 33  
8330 AA Steenwijk

Tel. 0521 - 534911  
Fax 0521 -534371

**Production location**  
Dyka B.V.  
Produktieweg 7  
Postbus 33  
8330 AA Steenwijk

Tel. 0521 - 534911  
Fax 0521 -534371

**Production location**  
Dyka Plastics N.V.  
Stuifzandstraat 47  
3900 Overpelt  
België

Tel. +32 11800430  
Fax +32 11661280



Evaluated is:  
quality system  
product  
Periodic inspection

## Three-layer PVC pipes for underground sewerage 110 - 630 mm

---

### PRODUCT SPECIFICATION

#### General

Three-layer PVC pipes for non-pressure underground sewerage in accordance with BRL 2023.

#### Technical specification of the product

Pipes with a smooth inner and outer wall, connected with each other by means of a layer of PVC.

#### Dimensions and classes

The dimensions and classes as indicated in the table below belong to this product certificate.

Nominal outside diameter in mm	Dyka B.V.		Dyka Plastics N.V.	
	SN 8	SN 4	SN 8	SN 4
110	X	X		
125	X	X		
160	X	X		
200	X	X		
250	X	X	X	X
315	X	X	X	X
400	X	X	X	X
500	X	X		
630	X	X		

#### Marking

The products are marked with the KOMO<sup>®</sup>-mark.

The realization of the mark is as follows: clear and indelible imprint.

Place of the mark: on each pipe at intervals of not more than 1,0 meter.

Compulsory indications;

- word mark KOMO<sup>®</sup>;
- manufacturer's name or registered trade mark;
- material indication: PVC;
- field of application: BRL 2023;
- nominal diameter;
- class indication SN;
- extruder number \*;
- production period \*.

\* Extruder number and production period may also be given in code.

## Three-layer PVC pipes for underground sewerage 110 - 630 mm

---

### RECOMMENDATIONS FOR USERS

The products are intended to be applied in plastics piping systems for non-pressure underground sewerage and drainage. Hereby the following application conditions must be taken into account:  
NPR 3218 "Non-pressure underground sewerage and drainage. Construction and maintenance";  
the installation instructions of the producer.

Check at the time of delivery whether:

- the products are in accordance with the agreement;
- the mark and marking method are correct;
- the products show no visible defects as a result of e.g. transport.

If you should reject a product on the basis of the above, please contact:

- Dyka B.V.

and, if necessary:

- Kiwa Nederland B.V.

Consult the installation instructions of the producer for the correct way of storage, transport and processing of the products.